

Submitted:-

The applicant applied permission for construction of first floor R.C.C building on existing ground floor bearing Mpl. No. 2-8-1/B, situated at Hyderabad road, Jangaon.

Inspected the site and found that, the applicant ~~site~~ has obtained permission for construction of ground floor R.C.C building vide proceedings no. H/262/1997, Dt. 3-4-97, but the party has constructed the against the sanction plan. i.e. not left the front open and north side open. Further the applicant has applied permission for construction of first floor R.C.C building plans are not satisfying the G.O.Ms. No. 168, MA, Dt. 7-4-2012.

Hence the applied permission may be rejected and the same may be intimated to the applicant accordingly.

S.F.O.

15/6/15

TPS.

Co. Secy.