

Submitted:-

Kindly peruse the Building application of Sri. S. Buchi Reddy S/o. Sri. Raji Reddy in the open land in Sy.No.19 & 20 of Gopalpur(V) situated at Gopalpur, Hanamkonda, Warangal Dist. for seeking permission for construction of Ground & First floor Residential Building in an extent of Net Plot area 150.63 Sq.mts.

In this connection, I have scrutinized & inspected the site and observed that, the applicant has submitted registered Agreement of Sale cum GPA document No.3658/2016, Registered Sale deed document No.1595/2004 and the proposed site is abutting to 30'-0" wide road on West & existing 18'-0" wide road on North, which proposed s 30'-0" wide road, wherein the proposed site of an area is 175.58 Sq.mts. is affecting 1.82 mts. depth to an extent of 24.95 Sq.mts. and net plot area 150.63 Sq.mts. for which the applicant has enclosed road affected area undertaking duly handing over at free of cost, but the proposed site is not covered by any approved Lay-Out & the applicant has not submitted LRS Proceedings and the proposed site measurements are not tallying on the ground position.

Therefore, in view of the above reasons, the permission may be rejected and intimated the applicant accordingly and also directed the applicant not to commence the construction work in the site under reference until further orders. | A

S.F.O

[Signature]
16/5/2015
T.P.B.o/c

[Signature]
A.C.P.

'A'
Agreed
D.C.R.
19/5